

## **Local Amendments to the 2006 International Fuel Gas Code**

1. Section 403.5.4 is amended by adding the following language:

*“Corrugated stainless tubing shall not be used for gas meter stub-out piping or installations where not adequately protected.”*

2. Section 109 is hereby amended by deletion and replacing with the following language:

“Section 109 Board of Appeals. The Board of Appeals as referenced in the adopted building code shall serve as the board of appeals for the Fuel Gas Code.”