

FIRE PUMP INSPECTION

- Water supply to the fire pump adequate to meet fire pump requirements
- Water supply to fire pump added to the fire pump rating meets or exceeds the demands
- Centrifugal fire pump listed for, and used exclusively for, fire protection service
- Change in installation since last inspection
- Guards provided for the flexible couplings and flexible connecting shafts in good order
- Required rated building construction housing the fire pump intact
- Suitable means for maintaining 40⁰ F being provided; 70⁰ F if driver is diesel engine
- Both normal lighting and emergency lighting maintained for pump room/house
- Pump room/house adequately ventilated
- All valves in the fire pump piping (except the test header valve) normally open
- Suction piping compound and the discharge pressure gauges appear operative
- Circulating relief valve functions properly
- For diesel engine driver, storage battery units maintained
- For diesel engine driver, battery charger units maintained
- For diesel driven pumps, fuel level is appropriate
- All alarms functional
- Approved vendor serviced fire pump in the past 12 months
- Annual fire pump test conducted
- Copy of annual inspection by approved vendor provided
- Pump performance meets or exceeds the demands of the systems supplied by pump